

## Mount Allison University Potable Water Sampling Program - Dunn Building

Guideline for Canadian Drinking Water Quality: 10 ug/L

| Location ID | Location Description                   | Lead Concentration ug/L |             |
|-------------|--|-------------------------|-------------|
|             |  | 17-May                  |             |
|             |  | 1st Reading             | 2nd Reading |
| Dunn 1      | 1st floor - fountain                   | <0.50                   | -           |
| Dunn 2      | 109 A female washroom sink 2 (left)    | <0.50                   | -           |
| Dunn 3      | 109 A female washroom sink 1 (right)   | <0.50                   | -           |
| Dunn 4      | 1st floor male washroom sink 2         | <0.50                   | -           |
| Dunn 5      | 2nd floor - kitchenette (Room 228)     | <0.50                   | -           |
| Dunn 6      | 219 A male washroom                    | <0.50                   | -           |
| Dunn 7      | 219 B female washroom                  | <0.50                   | -           |
| Dunn 8      | 210 shared research room sink          | 1.0                     | -           |
| Dunn 9      | 3rd floor - room 316                   | 2.9                     | -           |
| Dunn 10     | 3rd floor - room 309                   | 2.9                     | -           |
| Dunn 11     | 3rd floor - room 308 teaching lab sink | 2.2                     | -           |
| Dunn 12     | 315 A female washroom sink 1 (left)    | 1.3                     | -           |
| Dunn 13     | 315 A female washroom sink 2 (right)   | 1.1                     | -           |
| Dunn 14     | 315 B male washroom                    | <0.50                   | -           |
| Dunn 15     | 411 A female washroom sink 1 (left)    | 1.2                     | -           |
| Dunn 16     | 411 A female washroom sink 2 (right)   | 4.7                     | -           |
| Dunn 17     | 411 B Male washroom                    | <0.50                   | -           |
| DUP5        | Blind Field Duplicate of Dunn 5        | <0.50                   | -           |

**Value**

- Exceeds Health Canada Guidelines for Drinking Water Quality of 10ug/L

**Mount Allison University Potable Water Sampling Program**  
**- Edwards House**

Guideline for Canadian Drinking Water Quality: 10 ug/L

| Location ID | Location Description                    | Lead Concentration ug/L |             |
|-------------|---|-------------------------|-------------|
|             |   | 17-May                  |             |
|             |   | 1st Reading             | 2nd Reading |
| Edwards 1   | 3rd floor - bathroom 1 (307 Right sink) | 29                      | <0.50       |
| Edwards 2   | 3rd floor - bathroom 2 (307 Left sink)  | 16                      | <0.50       |
| Edwards 3   | 3rd floor - bathroom 3 (316 Right)      | 12                      | 0.87        |
| Edwards 4   | 3rd floor - bathroom 4 (316 Left)       | 12                      | <0.50       |
| Edwards 5   | 3rd floor - bathroom 5 (318 Right)      | 14                      | <0.50       |
| Edwards 6   | 3rd floor - bathroom 6 (318 Left)       | 5.4                     | -           |
| Edwards 7   | 3rd floor - bathroom 7 (329 Right)      | 1.4                     | -           |
| Edwards 8   | 3rd floor - bathroom 8 (329 Left)       | 1.4                     | -           |
| Edwards 9   | 3rd floor - kitchen 1 (327)             | 5.1                     | -           |
| Edwards 10  | 3rd floor - kitchen 2 (315)             | 7.9                     | -           |
| Edwards 11  | 2nd floor - bathroom 1 (229 Right)      | 5.8                     | -           |
| Edwards 12  | 2nd floor - bathroom 2 (229 Left)       | 2.8                     | -           |
| Edwards 13  | 2nd floor - bathroom 3 (218 Right)      | 2.2                     | -           |
| Edwards 14  | 2nd floor - bathroom 4 (218 Left)       | 4.1                     | -           |
| Edwards 15  | 2nd floor - bathroom 5 (216 Right)      | 5.0                     | -           |
| Edwards 16  | 2nd floor - bathroom 6 (216 Left)       | 3.9                     | -           |
| Edwards 17  | 2nd floor - bathroom 7 (207 Right)      | 8.4                     | -           |
| Edwards 18  | 2nd floor - bathroom 8 (207 Left )      | 7.9                     | -           |
| Edwards 19  | 2nd floor - kitchen 1 (215)             | 2.8                     | -           |
| Edwards 20  | 2nd floor - kitchen 2 (227)             | 1.8                     | -           |
| Edwards 24  | 1st floor - bathroom 4 (107 Right)      | 1.6                     | -           |
| Edwards 25  | 1st floor - bathroom 5 (107 Left)       | 2.0                     | -           |
| Edwards 26  | 1st floor - bathroom 6 (118 Right)      | 1.8                     | -           |
| Edwards 27  | 1st floor - bathroom 7 (118 Left)       | 1.2                     | -           |
| Edwards 28  | 1st floor - bathroom 8 (120 Right)      | 4.7                     | -           |
| Edwards 29  | 1st floor - bathroom 9 (120 Left)       | 1.9                     | -           |
| Edwards 30  | 1st floor - kitchen 1 (132)             | 2.7                     | -           |
| Edwards 31  | 1st floor - kitchen 2 (110)             | 0.9                     | -           |
| Edwards 32  | Basement kitchen (G13)                  | 1.5                     | -           |
| Edwards 33  | Staff Bathroom (rm G12)                 | 5.4                     | -           |
| Edwards 34  | Bathroom G17 Sink left                  | 17                      | 0.87        |
| Edwards 35  | Bathroom G17 Sink right                 | 3.4                     | -           |
| Edwards 39  | Dons apartment kitchen                  | 1.5                     | -           |
| Edwards 40  | Dons apartment washroom                 | 0.99                    | -           |
| DUP6        | Blind Field Duplicate of Edwards 9      | 5.5                     | -           |
| DUP7        | Blind Field Duplicate of Edwards 30     | 2.7                     | -           |

**Value**

- Exceeds Health Canada Guidelines for Drinking Water Quality of 10ug/L

## Mount Allison University Potable Water Sampling Program - Facilities Management Building

Guideline for Canadian Drinking Water Quality: 10 ug/L

| Location ID | Location Description          | Lead Concentration ug/L |             |
|-------------|-------------------------------|-------------------------|-------------|
|             |                               | 17-May                  |             |
|             |                               | 1st Reading             | 2nd Reading |
| FM 1        | Kitchen 110                   | 0.80                    | -           |
| FM 2        | Main floor men's washroom     | 2.8                     | -           |
| FM 3        | Main floor women's washroom   | 1.6                     | -           |
| FM 4        | Ground floor washroom         | 0.77                    | -           |
| FM 5        | Kitchen G8                    | 0.58                    | -           |
| FM 6        | HVAC shop                     | 1.9                     | -           |
| FM 7        | Plumbing Shop                 | <b>19</b>               | <0.50       |
| FM 8        | Kitchen Heating Plant         | 1.6                     | -           |
| DUP1        | Blind Field Duplicate of FM 7 | <b>18</b>               | -           |

**Value**

- Exceeds Health Canada Guidelines for Drinking Water Quality of 10ug/L

**Mount Allison University Potable Water Sampling Program**  
**- Fawcett Building**

Guideline for Canadian Drinking Water Quality: 10 ug/L

|             |                                     | Lead Concentration ug/L |             |
|-------------|-------------------------------------|-------------------------|-------------|
|             |                                     | 17-May                  |             |
| Location ID | Location Description                | 1st Reading             | 2nd Reading |
| Fawcett 1   | Grounds shop - Kitchen              | <0.50                   | -           |
| Fawcett 2   | Grounds shop - Water fountain       | <0.50                   | -           |
| DUP2        | Blind Field Duplicated of Fawcett 2 | <0.50                   | -           |

**Value** - Exceeds Health Canada Guidelines for Drinking Water Quality of 10ug/L

**Mount Allison University Potable Water Sampling Program**  
**-Flemington Building**

Guideline for Canadian Drinking Water Quality: 10 ug/L

| LocationID    | Location Description   | Lead Concentration |             |
|---------------|--|--------------------|-------------|
|               |  | 17-May             |             |
|               |  | 1st Reading        | 2nd Reading |
| Flemington 1  | Drinking fountain main floor.  | <0.50              | -           |
| Flemington 2  | Kitchen sink, second floor staff room (room 107). Coffee machine on counter. | 1.5                | -           |
| Flemington 3  | Second floor bathroom sink. Single person bathroom, beside room 207.         | 8.6                | -           |
| Flemington 4  | Sea lab room 15. Kitchen type sink.  | 0.63               | -           |
| Flemington 5  | Ladies washroom room 10. Sink on left.                                       | 1.1                | -           |
| Flemington 6  | Ladies washroom room 10. Sink on right.                                      | 1.6                | -           |
| Flemington 7  | Men's washroom Room 9. Sink on left.   | 0.74               | -           |
| Flemington 8  | Men's washroom Room 9. Sink on right.  | <0.50              | -           |
| Flemington 9  | Microbial lab room 4. Lab sink.  | 2.0                | -           |
| Flemington 10 | Teaching & Research lab room 113. Kitchen style sink in middle of lab.       | 5.5                | -           |
| Flemington 11 | Teaching & Research lab room 113. Kitchen style sink right.                  | 5.9                | -           |
| Flemington 12 | Teaching & Research lab room 113. Kitchen style sink left.                   | <b>24</b>          | 0.96        |
| Flemington 13 | Room 104 Susie Currie's Office.  | 6.2                | -           |
| Flemington 14 | Limology lab room 102. Town water faucet on lab style sink. (Middle)         | 0.65               | -           |
| Flemington 15 | Limology lab room 102. Town water faucet on lab style sink. (Right)          | 0.70               | -           |
| Flemington 16 | Research lab room 211. Kitchen style sink across from door.                  | 4.8                | -           |
| Flemington 17 | Research lab room 211. Kitchen style sink right of door.                     | 2.3                | -           |
| Flemington 18 | Dry lab room 13A. Lab style sink.  | 3.9                | -           |
| Flemington 19 | Room 16 kitchen style sink.  | 4.7                | -           |
| Flemington 20 | Teaching lab room 117. Lab sink left faucet closest to door.                 | 4.2                | -           |
| Flemington 21 | Teaching lab room 117. Lab sink left faucet farthest from door.              | <b>11</b>          | <0.50       |
| Flemington 22 | Office room 122 lab sink.  | <b>75</b>          | 3.9         |
| Flemington 23 | Teaching Lab room 213 lab sink next to door.                                 | 1.1                | -           |
| Flemington 24 | Teaching Lab room 213 lab sink back right corner (Left faucet).              | 3.1                | -           |
| Flemington 25 | Teaching Lab room 213 lab sink to left of door.                              | 1.9                | -           |
| Flemington 26 | Washroom room next to 208.   | 2.2                | -           |
| Flemington 27 | Room 202 right tap.  | <b>52</b>          | 0.56        |
| Flemington 28 | Research lab room 219 lab sink closest to door.                              | 4.2                | -           |
| Flemington 29 | Research lab room 219 lab sink farthest from door.                           | 1.5                | -           |
| Flemington 30 | Room 309 lab sink.   | 6.0                | -           |
| Flemington 31 | Room 305 lab sink.   | 2.4                | -           |
| Flemington 32 | Men's Washroom room 313 sink.  | 3.4                | -           |
| Flemington 33 | Women's Washroom room 314 sink.  | 3.6                | -           |
| Flemington 34 | Room 304. Sink to the right.   | 1.2                | -           |
| Flemington 35 | Room 304. Sink to the left corner.   | 1.6                | -           |
| Flemington 36 | Room 304. Sink around corner across from sample 55.                          | <b>17</b>          | 0.62        |
| Flemington 37 | Room 311 lab sink.   | 4.4                | -           |
| Flemington 38 | Department Head's office (room 218)  | 7.1                | -           |
| Flemington 39 | MACWI 1 - To right of greenhouse door, room 101.                             | <0.50              | -           |
| Flemington 40 | MACWI 2 - room 206   | 0.60               | -           |
| DUP3          | Blind Field Duplicate of Flemington 25                                       | 1.1                | -           |
| DUP4          | Blind Field Duplicate of Flemington 39                                       | <0.50              | -           |
| DUP1-II       | Blind Field Duplicate of Flemington 27 - 2nd Reading                         | <0.50              | 0.76        |

**Value**

- Exceeds Health Canada Guidelines for Drinking Water Quality of 10ug/L