

Mount Allison University Potable Water Sampling Program - Athletic Centre

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
AC 1	Lower level fountain - pool area	<0.1	
AC 2	Lower level fountain - outside weight room	<0.1	
AC 3	Main floor fountain	<0.1	
AC 4	2nd floor kitchen	4.5	
AC 5	Outside tap - edge of building by MacAulay Field	10.3	0.3

Value - Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program - Avard-Dixon Building

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Avard Dixon 1	Avard-Dixon G2 – Male washroom sink 1	5.8	0.2
Avard Dixon 2	Avard-Dixon G2 – Male washroom sink 2	3.3	
Avard Dixon 3	Avard-Dixon G2 – Male washroom sink 3	2.1	
Avard Dixon 4	Avard-Dixon G2 – Male washroom sink 4	2.4	
Avard Dixon 5	Avard-Dixon 109 – Female washroom	4.4	
Avard Dixon 6	Avard-Dixon 1 st floor hallway – water fountain	<0.1	
Avard Dixon 7	Avard-Dixon 210 – Male washroom	1.8	
Avard Dixon 8	Avard-Dixon 200 – Female washroom sink 1	13.8	0.7
Avard Dixon 9	Avard-Dixon 200 – Female washroom sink 2	6.3	0.3
Avard Dixon 10	Avard-Dixon 200 – Female washroom sink 3	9.8	0.6
Avard Dixon 11	Avard-Dixon 200 – Female washroom sink 4	4.5	
Avard Dixon 12	2 nd floor kitchenette - 228	5.5	0.8
Avard Dixon 13	Avard-Dixon 303 – Male washroom	1.2	
Avard Dixon 14	3 rd floor kitchenette - 310	0.2	
Avard Dixon 15	Avard-Dixon 330 – Female washroom	1.8	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program - Barclay Building

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Barclay 1	Basement - female washroom sink 1	0.7	
Barclay 2	Basement - female washroom sink 2	0.7	
Barclay 3	Basement - male washroom sink 1	0.8	
Barclay 4	1st floor - male washroom sink 1	0.6	
Barclay 5	1st floor - female washroom sink 1	0.6	
Barclay 6	1st floor - female washroom sink 2	0.5	
Barclay 7	1st floor - Room 113 (lounge)	0.6	
Barclay 8	1st floor hydration station fountain	<0.1	
Barclay 9	2nd Floor - gender neutral washroom sink 1	1.1	
Barclay 10	2nd floor - gender neutral washroom sink 2	0.7	
Barclay 11	2nd floor - gender neutral washroom sink 3	0.5	
Barclay 12	3rd floor - gender neutral washroom sink 1	0.5	
Barclay 13	3rd floor - gender neutral washroom sink 2	0.3	
Barclay 14	3rd floor - gender neutral washroom sink 3	0.4	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

**Mount Allison University Potable Water Sampling Program
- Bennett Building**

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Bennett Building 1	Basement - male sink 1 (left)	8.3	0.1
Bennett Building 2	Basement - male sink 2 (right)	1.3	
Bennett Building 3	Basement - female sink 1 (left)	4.0	
Bennett Building 4	Basement - female sink 2 (right)	4.0	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program

- The Anchorage

Guideline for Canadian Drinking Water Quality: 5 ug/L

		Lead Concentration ug/L	
Location ID	Location Description	1st Reading	2nd Reading
Anchorage 1	3rd floor washroom	5.5	0.2
Anchorage 2	2nd floor washroom 1 - 205	5.7	0.2
Anchorage 3	2nd floor washroom 2 - 203b	7.1	0.4
Anchorage 4	2nd floor washroom 3 - 202	3.5	
Anchorage 5	2nd floor washroom 4 - 206a	4.2	
Anchorage 6	1st floor kitchen	1.0	
Anchorage 7	1st floor washroom 1 - 106	1.0	
Anchorage 8	1st floor washroom 2 - 105	3.2	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program

- Bennett House

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Bennett House 1	Ground floor kitchen (G10)	1.9	
Bennett House 2	Washroom 1 (rm 107/109)	1.7	
Bennett House 3	Washroom 2 (126)	1.3	
Bennett House 4	Washroom 3 (127)	1.9	
Bennett House 5	Washroom 4 (128)	1.1	
Bennett House 6	Washroom 5 (129)	0.7	
Bennett House 7	Washroom 6 (133)	10.4	<0.1
Bennett House 8	Washroom 7 (134)	0.5	
Bennett House 9	Washroom 8 (135)	0.6	
Bennett House 10	Washroom 9 (137)	0.2	
Bennett House 11	Washroom 10 (rm 207/209)	2.3	
Bennett House 12	Washroom 11 (226)	1.2	
Bennett House 13	Washroom 12 (227)	1.0	
Bennett House 14	Washroom 13 (228)	0.9	
Bennett House 15	Washroom 14 (229)	0.8	
Bennett House 16	Washroom 15 (233)	6.4	<0.1
Bennett House 17	Washroom 16 (234)	1.7	
Bennett House 18	Washroom 17 (235)	1.8	
Bennett House 19	Washroom 18 (237)	0.9	
Bennett House 20	Washroom 19 (rm 307/309)	0.6	
Bennett House 21	Washroom 20 (326)	5.3	<0.1
Bennett House 22	Washroom 21 (327)	1.1	
Bennett House 23	Washroom 22 (328)	1.1	
Bennett House 24	Washroom 23 (329)	1.2	
Bennett House 25	Washroom 24 (333)	0.9	
Bennett House 26	Washroom 25 (334)	1.4	
Bennett House 27	Washroom 26 (335)	1.8	
Bennett House 28	Washroom 27 (337)	2.0	
Bennett House 29	Dons apartment kitchen	0.2	<0.1
Bennett House 30	Dons apartment washroom	0.6	<0.1

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program

- Bermuda House

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Bermuda 1	2nd floor washroom 1 - by stairwell	1.4	
Bermuda 2	2nd floor washroom 2 - down hall	2.1	
Bermuda 3	Main floor kitchen	1	
Bermuda 4	Main floor washroom 1 - by kitchenette	4.3	
Bermuda 5	Main floor washroom 2 - by window	3.2	
Bermuda 6	Main floor washroom 3 - by stairwell	0.5	
Bermuda 7	Main floor washroom 4 - down hall	1.5	
Bermuda 8	Basement washroom 1 - end of hall	3.7	
Bermuda 9	Basement washroom 2 - end of hall on right	4.8	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program

- Bigelow House

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Bigelow 1	3rd floor - bathroom 1 - Rm. 312C	1.3	
Bigelow 2	3rd floor - bathroom 2 - Rm. 312A	1.0	
Bigelow 3	3rd floor - bathroom 3 - Rm. 320	1.5	
Bigelow 4	3rd floor - bathroom 4 - Rm. 321	0.5	
Bigelow 5	3rd floor - bathroom 5 - Rm. 317	9.7	0.3
Bigelow 6	3rd floor - bathroom 6 - Rm. 313	14.7	4.0
Bigelow 7	3rd floor - bathroom 7	3.8	
Bigelow 8	3rd floor - bathroom 8 - Rm. 309	2.0	
Bigelow 9	3rd floor - bathroom 9 - Rm. 303	1.4	
Bigelow 10	3rd floor - bathroom 10 - Rm. 304	0.4	
Bigelow 11	2nd floor - bathroom 1 - Rm. 212C	1.1	
Bigelow 12	2nd floor - bathroom 2 - Rm. 212A	0.9	
Bigelow 13	2nd floor - bathroom 3 - Rm. 220	0.3	
Bigelow 14	2nd floor - bathroom 4 - Rm. 221	0.5	
Bigelow 15	2nd floor - bathroom 5 - Rm. 217	20.3	1.1
Bigelow 16	2nd floor - bathroom 6 - Rm. 213	11.6	0.9
Bigelow 17	2nd floor - bathroom 7 - Rm. 209	2.5	
Bigelow 18	2nd floor - bathroom 8 - Rm. 205	5.1	0.1
Bigelow 19	2nd floor - bathroom 9 - Rm. 203	0.9	
Bigelow 20	2nd floor - bathroom 10 - Rm. 204	0.6	
Bigelow 21	1st floor - bathroom 1 - Rm. 112C	0.6	
Bigelow 22	1st floor - bathroom 2 - Rm. 112A	0.5	
Bigelow 23	1st floor - bathroom 3 - Rm. 120	0.5	
Bigelow 24	1st floor - bathroom 4 - Rm. 121	0.6	
Bigelow 25	1st floor - bathroom 5 - Rm. 117	2.0	
Bigelow 26	1st floor - bathroom 6 - Rm. 113	3.9	
Bigelow 27	1st floor - bathroom 7 - Rm. 109	3.2	
Bigelow 28	1st floor - bathroom 8 - Rm. 105	2.7	
Bigelow 29	1st floor - bathroom 9 - Rm. 103	0.4	
Bigelow 30	1st floor - bathroom 10 - Rm. 104	0.3	
Bigelow 31	1st floor - hydration student	<0.1	
Bigelow 32	Basement kitchen	0.5	
Bigelow 33	Basement washroom 1	0.9	
Bigelow 34	Basement washrrom 2	0.4	
Bigelow 35	Basement washroom 3	0.5	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program
- Carriage House

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Carriage 1	2nd floor washroom 1 - left sink	4.6	
Carriage 2	2nd floor washroom 2 - right sink	5.7	0.2
Carriage 3	1st floor washroom 1 - left sink	18.2	1.6
Carriage 4	1st floor washroom 2 - right sink	2.0	
Carriage 5	Basement kitchen	0.9	
Carriage 6	Basement washroom	3.0	

Value - Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L