

Mount Allison University Potable Water Sampling Program

- Campbell Hall

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L		
		1st Reading	2nd Reading	3rd Reading
Campbell 1	Don's apartment	0.6		
Campbell 2	Don's apartment	1.8		
Campbell 3	4th floor - bathroom 1 - Rm. 432	2.4		
Campbell 4	4th floor - bathroom 2 - Rm. 426	2		
Campbell 5	4th floor - bathroom 3 - Rm. 412	1.6		
Campbell 6	4th floor - bathroom 4 - Rm. 414	4.2		
Campbell 7	4th floor - bathroom 5 - Rm. 410	2.4		
Campbell 8	4th floor - bathroom 6 - Rm. 406	16.5	16.1	0.6
Campbell 9	4th floor - bathroom 7 - Rm. 403	2.7		
Campbell 10	4th floor - bathroom 8 - Rm. 407	2.6		
Campbell 11	4th floor - bathroom 9 - Rm. 411	1.6		
Campbell 12	4th floor - bathroom 10 - Rm. 415	1.5		
Campbell 13	4th floor - bathroom 11 - Rm. 419	1.9		
Campbell 14	4th floor - bathroom 12 - Rm. 423	1.7		
Campbell 15	4th floor - bathroom 13 - Rm. 425	4.1		
Campbell 16	4th floor - bathroom 14 - Rm. 431	2.5		
Campbell 17	4th floor - bathroom 15 - Rm. 435	2.6		
Campbell 18	4th floor - bathroom 16 - Rm. 437	2.7		
Campbell 19	4th floor - bathroom 17 - Rm. 443	3.3		
Campbell 20	4th floor - bathroom 18 - Rm. 447	2.5		
Campbell 21	4th floor - bathroom 19 - Rm. 451	1.9		
Campbell 22	4th floor - bathroom 20 - Rm. 453	6.1	0.3	
Campbell 23	4th floor - bathroom 21 - Rm. 446	6.6	0.2	
Campbell 24	4th floor - bathroom 22 - Rm. 440	11.2	0.1	
Campbell 25	4th floor - bathroom 23 - Rm. 436	1.8		
Campbell 26	4th floor kitchen	0.5		
Campbell 27	3rd floor - bathroom 1 - Rm. 330	1.3		
Campbell 28	3rd floor - bathroom 2 - Rm. 326	1.2		
Campbell 29	3rd floor - bathroom 3 - Rm. 318	1.3		
Campbell 30	3rd floor - bathroom 4 - Rm. 314	1.8		
Campbell 31	3rd floor - bathroom 5 - Rm. 310	1.6		
Campbell 32	3rd floor - bathroom 6 - Rm. 306	1.2		
Campbell 33	3rd floor - bathroom 7 - Rm. 303	12.1	<0.1	
Campbell 34	3rd floor - bathroom 8 - Rm. 307	5.0	<0.1	
Campbell 35	3rd floor - bathroom 9 - Rm. 311	2.3		
Campbell 36	3rd floor - bathroom 10 - Rm. 315	2.1		
Campbell 37	3rd floor - bathroom 11 - Rm. 319	1.4		

Mount Allison University Potable Water Sampling Program

- Campbell Hall

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L		
		1st Reading	2nd Reading	3rd Reading
Campbell 38	3rd floor - bathroom 12 - Rm. 323	4.3		
Campbell 39	3rd floor - bathroom 13 - Rm. 325	1.8		
Campbell 40	3rd floor - bathroom 14 - Rm. 331	1.0		
Campbell 41	3rd floor - bathroom 15 - Rm. 335	2.2		
Campbell 42	3rd floor - bathroom 16 - Rm. 337	8.6	0.2	
Campbell 43	3rd floor - bathroom 17 - Rm. 343	4.0		
Campbell 44	3rd floor - bathroom 18 - Rm. 347	6.6	0.3	
Campbell 45	3rd floor - bathroom 19 - Rm. 349	15.2	0.2	
Campbell 46	3rd floor - bathroom 20 - Rm. 353	33.2	0.2	
Campbell 47	3rd floor - bathroom 21 - Rm. 346	216.0	0.2	
Campbell 48	3rd floor - bathroom 22 - Rm. 340	2.5		
Campbell 49	3rd floor - bathroom 23 - Rm. 336	3.0		
Campbell 50	3rd floor kitchen	11.1	1.3	
Campbell 51	2nd floor - bathroom 1 - Rm. 230	4.5		
Campbell 52	2nd floor - bathroom 2 - Rm. 226	1.0		
Campbell 53	2nd floor - bathroom 3 - Rm. 218	29.2	0.1	
Campbell 54	2nd floor - bathroom 4 - Rm. 214	4.3		
Campbell 55	2nd floor - bathroom 5 - Rm. 210	6.3	<0.1	
Campbell 56	2nd floor - bathroom 6 - Rm. 206	5.8	0.5	
Campbell 57	2nd floor - bathroom 7 - Rm. 203	10.6	0.2	
Campbell 58	2nd floor - bathroom 8 - Rm. 207	21.0	0.1	
Campbell 59	2nd floor - bathroom 9 - Rm. 211	1.1		
Campbell 60	2nd floor - bathroom 10 - Rm. 215	1.0		
Campbell 61	2nd floor - bathroom 11 - Rm. 219	2.7		
Campbell 62	2nd floor - bathroom 12 - Rm. 221	6.9	<0.1	
Campbell 63	2nd floor - bathroom 13 - Rm. 225	2.8		
Campbell 64	2nd floor - bathroom 14 - Rm. 231	1.0		
Campbell 65	2nd floor - bathroom 15 - Rm. 235	1.7		
Campbell 66	2nd floor - bathroom 16 - Rm. 237	20.9	0.3	
Campbell 67	2nd floor - bathroom 17 - Rm. 243	4.3		
Campbell 68	2nd floor - bathroom 18 - Rm. 247	115.0	0.1	
Campbell 69	2nd floor - bathroom 19 - Rm. 251	1.2		
Campbell 70	2nd floor - bathroom 20 - Rm. 253	3.8		
Campbell 71	2nd floor - bathroom 21 - Rm. 246	122.0	0.8	
Campbell 72	2nd floor - bathroom 22 - Rm. 240	4.0		
Campbell 73	2nd floor - bathroom 23 - Rm. 236	11.1	<0.1	
Campbell 74	2nd floor kitchen	0.5		

Mount Allison University Potable Water Sampling Program

- Campbell Hall

Guideline for Canadian Drinking Water Quality: 5 ug/L

		Lead Concentration ug/L		
Location ID	Location Description	1st Reading	2nd Reading	3rd Reading
Campbell 75	1st floor - bathroom 1	7.0	<0.1	
Campbell 76	1st floor - bathroom 2 - Rm. 132	5.6	<0.1	
Campbell 77	1st floor - bathroom 3 - Rm. 128	3.8		
Campbell 78	1st floor - bathroom 4 - Rm. 118	12.7	10.7	<0.1>
Campbell 79	1st floor - bathroom 5 - Rm. 114	1.3		
Campbell 80	1st floor - bathroom 6 - Rm. 110	12.5	0.2	
Campbell 81	1st floor - bathroom 7 - Rm. 106	6.8	0.8	
Campbell 82	1st floor - bathroom 8 - Rm. 103	390.0	0.2	
Campbell 83	1st floor - bathroom 9 - Rm. 107	46.3	2.3	
Campbell 84	1st floor - bathroom 10 - Rm. 111	22.6	0.2	
Campbell 85	1st floor - bathroom 11 - Rm. 115	1.3		
Campbell 86	1st floor - bathroom 12 - Rm. 119	6.9	0.2	
Campbell 87	1st floor - bathroom 13 - Rm. 123	21.2	0.4	
Campbell 88	1st floor - bathroom 14 - Rm. 125	2.8		
Campbell 89	1st floor - bathroom 15 - Rm. 129	9.7	0.5	
Campbell 90	1st floor - bathroom 16 - Rm. 133	3.2		
Campbell 92	1st floor - bathroom 17 - Rm. 135	7.0	3	
Campbell 93	1st floor - bathroom 18 - Rm. 136	3.5		
Campbell 94	1st floor - bathroom 19 - Rm. 139	11.1	<0.1	
Campbell 95	1st floor kitchen	<0.1		

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program

- Centennial Hall

Guideline for Canadian Drinking Water Quality: 5 ug/L

		Lead Concentration ug/L	
Location ID	Location Description	1st Reading	2nd Reading
Centennial 1	Basement kitchen	0.5	
Centennial 2	Second floor kitchenette	1.1	
Centennial 3	Third floor bathroom	9.6	0.3

Mount Allison University Potable Water Sampling Program

- Colville House

Guideline for Canadian Drinking Water Quality: 5 ug/L

		Lead Concentration ug/L	
Location ID	Location Description	1st Reading	2nd Reading
Colville 1	Main floor - kitchen	9.0	0.7

Value - Exceeds Health Canada Guidelines for Drinking Water Quality of 5ug/L

Mount Allison University Potable Water Sampling Program

- Convocation Hall

Guideline for Canadian Drinking Water Quality: 5 ug/L

		Lead Concentration ug/L	
Location ID	Location Description	1st Reading	2nd Reading
Con Hall 1	Kitchen	10.0	1.4
Con Hall 2	Main floor fountain	0.1	

Value - Exceeds Health Canada Guidelines for Drinking Water Quality of 5 ug/L

Mount Allison University Potable Water Sampling Program

- Crabtree Building

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
Crabtree 1	B04 Washroom.	1.8	
Crabtree 2	Drinking fountain on Main Floor.	<0.1	
Crabtree 3	216 Faculty Lounge kitchen sink.	0.4	
Crabtree 4	318 Reading Room.	2.3	
Crabtree 5	B06 Washroom.	0.9	
Crabtree 6	G38 Ladies washroom. Left sink near stall.	5.9	0.4
Crabtree 7	G38 Ladies washroom. Right sink near door.	3.2	
Crabtree 8	G37 Mens washroom. Left sink.	2.3	
Crabtree 9	G37 Mens washroom. Right sink.	1.3	
Crabtree 11	G6 Rat Holding room.	4.2	
Crabtree 12	G2 Washroom.	12.9	0.2
Crabtree 13	G9 Fume hood room.	79.1	0.2
Crabtree 14	G20 Surgery room. Back wall sink.	13.8	0.6
Crabtree 15	G20 Surgery room. Sink closest door.	17.0	3.7
Crabtree 16	G12 Holding room.	9.8	3.2
Crabtree 17	G13	14.5	1.1
Crabtree 18	G16 Washing.	7.5	0.3
Crabtree 19	G7 Holding room.	77.9	3.8
Crabtree 20	M4 Ladies washroom. Left sink.	5.2	0.2
Crabtree 21	M4 Ladies washroom. Middle sink.	3.9	
Crabtree 22	M4 Ladies washroom. Right sink.	3.0	
Crabtree 23	M5 Mens washroom. Left sink.	8.8	0.3
Crabtree 24	M5 Mens washroom. Middle sink.	6.7	0.2
Crabtree 25	M5 Mens washroom. Right sink.	5.7	0.2
Crabtree 27	205 Womens washroom. Left sink.	0.1	
Crabtree 28	205 Womens washroom. Right sink.	0.2	
Crabtree 29	207 Mens washroom.	0.4	
Crabtree 32	303 Womens washroom. Left sink.	3.7	
Crabtree 33	303 Womens washroom. Right sink.	5.0	0.2
Crabtree 34	302 Mens washroom. Left sink.	0.8	
Crabtree 35	302 Mens washroom. Left Sink	4.6	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5 ug/L

Mount Allison University Potable Water Sampling Program

- Thornton House

Guideline for Canadian Drinking Water Quality: 5 ug/L

		Lead Concentration ug/L	
Location ID	Location Description	1st Reading	2nd Reading
Thornton 1	Ground floor - Room 024	1.8	
Thornton 2	Ground floor - Room 023	2.3	
Thornton 3	Ground floor - Room 022	1.3	
Thornton 4	Ground floor - Room 021 kitchen	2.0	
Thornton 5	Ground floor - Room 019	2.3	
Thornton 6	Ground floor - Room 015	1.0	
Thornton 7	Ground floor - Room 013	1.1	
Thornton 8	Ground floor - Room 012	1.2	
Thornton 9	Ground floor - Room 010	0.8	
Thornton 10	Ground floor - Room 008	1.6	
Thornton 11	Ground floor - Room 007 kitchen	0.6	
Thornton 12	Ground floor - Room 004	1.7	
Thornton 13	Ground floor - Room 003	0.4	
Thornton 14	Don's apartment kitchen	1.7	
Thornton 15	Don's apartment bathroom	0.9	
Thornton 16	1st floor - Room 120	1.7	
Thornton 17	1st floor - Room 118	1.6	
Thornton 18	1st floor - Room 117	1.9	
Thornton 19	1st floor - fountain	<0.1	
Thornton 20	1st floor - Room 114 public	0.8	
Thornton 21	1st floor - Room 113 public	0.7	
Thornton 22	1st floor - Room 112	1.7	
Thornton 23	1st floor - Room 111	2.7	
Thornton 24	1st floor - Room 109	1.1	
Thornton 25	1st floor - Room 107	0.9	
Thornton 26	1st floor - Room 105	1.6	
Thornton 27	1st floor - Room 104	0.9	
Thornton 28	1st floor - Room 103	1.2	
Thornton 29	2nd floor - Room 228 *	1.3	
Thornton 30	2nd floor - Room 226	2.0	
Thornton 31	2nd floor - Room 225 *	0.9	

Thornton 32	2nd floor - Room 223 *	0.8	
Thornton 33	2nd floor - Room 221	1.1	
Thornton 34	2nd floor - Room 220 kitchen	1.4	
Thornton 35	2nd floor - Room 219	1.6	
Thornton 36	2nd floor - Room 218	1.7	
Thornton 37	2nd floor - Room 215 public	0.4	
Thornton 38	2nd floor - Room 214 public	1.1	
Thornton 39	2nd floor - Room 213	1.6	
Thornton 40	2nd floor - Room 212	2.0	
Thornton 41	2nd floor - Room 210	2.6	
Thornton 42	2nd floor - Room 208	0.9	
Thornton 43	2nd floor - Room 205	2.0	
Thornton 44	2nd floor - Room 204	1.1	
Thornton 45	2nd floor - Room 203	1.3	
Thornton 46	3rd floor - Room 329	1.4	
Thornton 47	3rd floor - Room 327	0.5	
Thornton 48	3rd floor - Room 326	1.0	
Thornton 49	3rd floor - Room 324	0.9	
Thornton 50	3rd floor - Room 323	2.1	
Thornton 51	3rd floor - Room 321 kitchen	0.6	
Thornton 52	3rd floor - Room 320	1.2	
Thornton 53	3rd floor - Room 319	0.5	
Thornton 54	3rd floor - Room 316 public	0.5	
Thornton 55	3rd floor - Room 315 public	0.7	
Thornton 56	3rd floor - Room 314	1.2	
Thornton 57	3rd floor - Room 313	1.5	
Thornton 58	3rd floor - Room 311	1.0	
Thornton 59	3rd floor - Room 309	2.2	
Thornton 60	3rd floor - Room 306	1.0	
Thornton 61	3rd floor - Room 305	1.9	
Thornton 62	3rd floor - Room 303	0.6	

Value

- Exceeds Health Canada Guidelines for Drinking Water Quality of 5 ug/L